

Declaration of Performance

CONSTRUCTION PRODUCTS REGULATION 2011 DECLARATION OF PERFORMANCE

No. AL-0000425558

1. Unique identification code of the product-type:

Briton 6100 999 Double Door Coordinator (Size 3 to 5)

2. Type, batch or serial number or any other element allowing identification of the construction product as required under Article 11(4) of the CPR:

Briton 6100 999 Double Door Coordinator

3. Intended use or uses of the construction product, in accordance with the applicable harmonized technical specification, as foreseen by the manufacturer:

For use on fire and smoke compartmentation doors

4. Name, registered trade name or registered trade mark and contact address of the manufacturer as required under Article 11(5):

**Allegion (UK) Limited
35 Rocky Lane
Aston
Birmingham
B6 5RQ**

5. Where applicable, name and contact address of the authorised representative whose mandate covers the tasks specified in Article 12(2):

N/A

6. System or systems of assessment and verification of constancy of performance of the construction product as set out in CPR, Annex V:

System 1

7. In case of the declaration of performance concerning a construction product covered by a harmonized standard:

**EN 1158:1996/A1:2002/AC:2006
Notified Certification body No.1121 performed the type testing and issued test reports.
Certificate of Constancy of Performance - 1121-CPR- AF5003**

8. European Technical Assessment:

N/A

9. Declared performance


Essential characteristics	Performance	Harmonised technical specification
Self closing		
5.1 Product Information and design	Pass	
5.2.1 General		
5.2.2 Overload performance	Pass	
5.2.3 Manipulation performance	Pass	
5.2.4 Resistance of Waiting	Pass	
5.2.6 Damage	Pass	EN 1158:1997/A1:2002/AC:2006

5.2.8 Fire/smoke door suitability	Pass	
Essential characteristics	Performance	Harmonised technical specification
Durability of Self Closing 5.2.5 Durability 5.2.17.1 corrosion 5.2.17.2 corrosion Dangerous Substances Annex ZA3	(Grade 5) 500,000 test cycles Grade 3 (96 hours) Pass Pass: the materials in the door coordinator do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	EN 1158:1997/A1:2002/AC:2006

10. The performance of the product identified in points 1 and 2 is in conformity with the declared performance in point 9.

This declaration of performance is issued under the sole responsibility of the manufacturer identified in point 4.
Signed for and on behalf of the manufacturer by:

Chris Crampton
Controller - Unitary EMEA, Finance and Accounting



Allegion (UK) Limited
35 Rocky Lane
Aston
Birmingham
B6 5RQ

27th November 2017