

Notified Body No. 2812

## Certificate of Constancy of Performance

### 2812-CPR-AF5003

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

## Briton 6100 999.XXX / Bricard 6100 999X / Cisa 1.07155.61.0.XX Door Coordinators (Size 3 to 5)

**Intended use:** For use on fire rated double leaf doors

Essential characteristics	Performance	Harmonised technical specification
	Mechanical test Evidence : WIL 355825. Fire Test Evidence : WF No 358184	
Self closing	Pass	EN 1158:1997/A1:2002/AC:2006
5.1 Product Information and design		
5.2.1 General		
5.2.2 Overload performance		
5.2.3 Manipulation performance		
5.2.4 Resistance of Waiting		
5.2.6 Damage		
5.2.8 Fire/smoke door suitability	Pass	
Essential characteristics	Performance	Harmonised technical specification
Durability of Self Closing	(Grade 5)	EN 1158:1997/A1:2002/AC:2006
5.2.5 Durability	500,000 test cycles	
5.2.17.1 corrosion	(Grade 3) 96hrs	
5.2.17.2 corrosion	(Grade 3) 96hrs	
Dangerous Substances Annex ZA3	Pass: the materials in the door coordinator do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	

## Certificate of Constancy of Performance

**2812-CPR-AF5003**

Placed on the Market under the name of:

**Allegion (UK) Ltd  
35 Rocky Lane, Aston, Birmingham, B6 5RQ**

and produced in the manufacturing plant

**K/016**

**This is coded format and the information is held by the Notified Body.**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

**EN 1158:1996/A1:2002/AC:2006**

Under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **30/10/2020** and reissued **14/07/2021** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the notified product certification body.

Valid to: **13/07/2024**

ERO Project Reference: **ERO 034621 P1348**



Paul Duggan  
Certification Manager

CSF408-NL 5.0