



Notified body No. 1121

Certificate of constancy of performance

1121-CPR-AD5311

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Briton 131.XX, Bricard 61311XX, Cisa C1455.03.0.XX, ITO H131.XX & Falcon LA-C234 Overhead Door Closers

Intended use: For use on fire rated single leaf and double leaf doors STANDARD FIXING POSITION

Essential characteristics	Performance	Harmonised technical specification
	Test Ref's:	
	WIL 372423 & WF No 375469.	
Self closing		
5.2.1 General		EN 1154:1996/A1:2002/AC:2006
5.2.2 Durability	500,000 test cycles	
5.2.3 Closing moment	Pass size 2 to 4	
5.2.4 Opening moment	Pass size 2 to 4	
5.2.5 Efficiency	>50% size 2	
5.2.5 Efficiency	>60% size 4	
5.2.6 Closing time	Pass	
5.2.7 Angles of operation	Grade 3, >105°	
5.2.8 Overload performance	Pass	
5.2.9 Temperature dependence	-15°C to +40°C	
5.2.10 Fluid leakage	Pass	
5.2.11 Damage	Pass	
5.2.12 Latch control	Pass	
5.2.13 Back check (optional)	NPD	
5.2.14 Delayed closing (optional)	NPD	
5.2.15 Adjustable closing force	Pass	
(optional)		
5.2.16 Zero position (double	NPD	
action door closers only)		
5.2.18 Fire/smoke door suitability	Pass	
Essential characteristics	Performance	Harmonised technical
		specification
Durability of Self Closing		
5.2.2 Durability	500,000 test cycles	EN 1154:1996/A1:2002/AC:2006
5.2.17.1 corrosion	Grade 3 (96 hours)	
5.2.17.2 corrosion	Pass	
Dangerous Substances	Pass: the materials in the door closer do not	EN 1154.1996/A1.2002/AC.2006
Annex ZA3	contain or release any dangerous substances	
	in excess of the maximum levels specified in	
	existing European material standards or any	
	national regulations	

Page 1 of 3





Certificate of constancy of performance

1121-CPR-AD5311

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Briton 131.XX, Bricard 61311XX, Cisa C1455.03.0.XX, ITO H131.XX & Falcon C-234 Overhead Door Closers

Intended use: For use on fire rated single leaf and double leaf doors
PARALLEL ARM APPLICATION

PARALLEL ARM APPLICATION			
Essential characteristics	Performance	Harmonised technical specification	
Self closing			
5.2.1 General			
5.2.2 Durability	500,000 test cycles		
5.2.3 Closing moment	Pass size 3		
5.2.4 Opening moment	Pass size 3		
5.2.5 Efficiency	>55% size 3		
5.2.6 Closing time	Pass		
5.2.7 Angles of operation	Grade 3, > 105°		
5.2.8 Overload performance	Pass		
5.2.9 Temperature	-15°C to +40°C	EN 445 4:4000/44:0000/40:0000	
dependence		EN 1154:1996/A1:2002/AC:2006	
5.2.10 Fluid leakage	Pass		
5.2.11 Damage	Pass		
5.2.12 Latch control	NPD		
5.2.13 Back check (optional)	NPD		
5.2.14 Delayed closing	NPD		
(optional)			
5.2.15 Adjustable closing force	NPD		
(optional)			
5.2.16 Zero position (double	NPD		
action door closers only)			
5.2.18 Fire/smoke door	Pass		
suitability			
Essential characteristics	Performance	Harmonised technical	
		specification	
Durability of Self Closing		-	
5.2.2 Durability	500,000 test cycles		
5.2.17.1 corrosion	Grade 3 (96 hours)		
5.2.17.2 corrosion	Pass		
Dangerous Substances	Pass: the materials in the door closer	EN 1154:1996/A1:2002/AC:2006	
Annex ZA3	do not contain or release any		
THIOX ZAO	dangerous substances in excess of		
	the maximum levels specified in		
	existing European material standards		
	or any national regulations		
	or arry riational regulations	<u>L</u>	





Certificate of constancy of performance 1121-CPR-AD5311

Produced for

Allegion (UK) Ltd 35 Rocky Lane, Aston, Birmingham, B6 5RQ, UK

and produced in the manufacturing plant

K/002

This is coded format and the information is held by the Notified Body.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 1154:1996/A1:2002/AC:2006

under system 1 of AVCP are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on **06/01/17** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Paul Duggan
Certification Manager
Warrington Certification.

Exova (UK) Limited trading as Warrington Certification, Holmesfield Road, Warrington, Cheshire, WA1 2DS,UK

