

Notified body No. 1121

## Certificate of constancy of performance

### 1121-CPR-AF5003

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

## Briton 6100 999.XXX / Bricard 6100 999X / Cisa 07155.61.0.XX Door Coordinators (Size 3 to 5)

**Intended use:- For use on fire rated double leaf doors.**

Essential characteristics	Performance	Harmonised technical specification
	Test Ref's : WIL 355825 & WF No 358184	
Self closing		EN 1158:1997/A1:2002/AC:2006
5.1 Product Information and design	Pass	
5.2.1 General		
5.2.2 Overload performance	Pass	
5.2.3 Manipulation performance	Pass	
5.2.4 Resistance of Waiting	Pass	
5.2.6 Damage	Pass	
5.2.8 Fire/smoke door suitability	Pass	
Essential characteristics	Performance	Harmonised technical specification
Durability of Self Closing	(Grade 5)	EN 1158:1997/A1:2002/AC:2006
5.2.5 Durability	500,000 test cycles	
5.2.17.1 corrosion	(Grade 3) 96hrs	
5.2.17.2 corrosion	(Grade 3) 96hrs	
Dangerous Substances Annex ZA3	Pass: the materials in the door coordinator do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	

**Certificate of constancy of performance**

**1121-CPR-AF5003**

Produced for

**Allegion (UK) Ltd  
35 Rocky Lane  
Aston  
Birmingham  
B6 5RQ**

and produced in the manufacturing plant

**K/016**

**This is coded format and the information is held by the Notified Body.**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)


**EN 1158:1996/A1:2002/AC:2006**

under system 1 of AVCP are applied and that

***the product fulfils all the prescribed requirements set out above.***

This certificate was first issued on **10/01/18** and will remain valid to the date given below as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Valid to: **09/01/21**



Paul Duggan  
Certification Manager



Exova (UK) Limited Trading as Warrington Certification  
Holmesfield Road, Warrington, Cheshire. WA1 2DS, UK