

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AF5000

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

COR32 / COR42 / COR52 Door Coordinators (Size 3 to 6)

Intended use:- For use on fire rated single leaf and double leaf doors

Essential characteristics	Performance	Harmonised technical specification
	Test Ref's : WIL 331310 & WF No 334654.	
Self closing		
5.1 Product Information and design	Pass	
5.2.1 General		
5.2.2 Overload performance	Pass	
5.2.3 Manipulation performance	Pass	EN 1158:1997/A1:2002/AC:2006
5.2.4 Resistance of Waiting	Pass	
5.2.6 Damage	Pass	
5.2.8 Fire/smoke door suitability	Pass	
Essential characteristics	Performance	Harmonised technical specification
Durability of Self Closing	(Grade 5)	
5.2.5 Durability	50,000 test cycles	
5.2.17.1 corrosion	Grade 3 (96 hours)	
5.2.17.2 corrosion	Pass	
Dangerous Substances Annex ZA3	Pass: the materials in the door coordinator do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	EN 1158:1997/A1:2002/AC:2006

Certificate of Constancy of Performance

2812-CPR-AF5000

Placed on the Market under the name of:

Allegion (UK) Ltd
Bescot Crescent, Walsall. West Midlands. WS1 4DL

and produced in the manufacturing plant

B/005

This is coded format and the information is held by the Notified Body.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 1158:1996/A1:2002/AC:2006

Under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on 30/10/2020 and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the notified product certification body.

Valid to: **31/10/2022**

ERO Project Reference: **EROWF10081**



Paul Duggan
Certification Manager

