



CERTIFICATE OF APPROVAL

No CF 109

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

ALLEGION (UK) LIMITED

35 Rocky Lane, Aston, Birmingham, B6 5RQ, UK
+44 (0) 121 380 2400

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

Briton 996 Series
Overhead Door Closers

TECHNICAL SCHEDULE

TS 34 - The Contribution Of
Controlled Door Closing
Devices And Accessories To
Fire Resisting Doorsets

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager



Issued: 25th February 2021
Audit Test Frequency: Annually
Valid to: 24th February 2026



ALLEGION (UK) LIMITED No CF 109

BRITON 996 SERIES OVERHEAD DOOR CLOSERS

- This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
- This approval relates to the following door closing devices and configurations:

Briton Product References	Link-arms			Slide arms			
	Projecting arm (Fig. 1) Body door mounted on pull face	Projecting arm (Fig. 61) Body transom mounted on push face	Parallel arm (Fig. 6) Body door mounted on push face	Body door mounted on pull face	Body transom mounted on push face	Body door mounted on push face	Body transom mounted on pull face
9963	✓	✓	✓	✗	✗	✗	✗
9964	✓	✓	✓	✗	✗	✗	✗
9965	✓	✓	✓	✗	✗	✗	✗

Key: ✓ - approved ✗ - Not approved

Note: Where alternative arms for non-fire applications are included within the packaging, the use of these components on fire resisting door assemblies will invalidate the certification.

- This approval relates to their use with the following door assemblies:-
Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 120 minutes (Code ITT).
- The closers are approved on the basis of:
 - Initial type testing to EN1154/1155 and BS EN 1634-1
 - An appraisal against TS34
 - Certification of quality management system
 - Inspection and surveillance of factory production control
 - On-going audit testing in accordance with EN 1154 requirements
- The closers shall be fixed with screws supplied by the closer manufacturer. Bolt-through fixings shall not be used.



ALLEGION (UK) LIMITED

CF 109

BRITON 996 SERIES OVERHEAD DOOR CLOSERS

6. Where the closers are fitted to door leaves or frames that are manufactured from mineral composite-based materials, or low-density cellulosic-based material, the door assembly shall have previously been shown capable of accommodating the installation of closers at the head of the doorset, without detriment to the door assembly's performance.
7. This approval is applicable only to the specified closers when mounted in the applications stated above and under the classification codes section of this certificate and used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987) and having power ratings appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).
8. The approval relates to on-going production. The product and/or its immediate packaging are identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate

ALLEGION (UK) LIMITED CF 109

BRITON 996 SERIES OVERHEAD DOOR CLOSERS

9. The following tables show acceptable doorset types and fire resistance periods:

Class	Approved Door Type				
	MM	IMM	ITT	ITM	ITC
FD20	x	x	✓	x	x
FD30	x	x	✓	x	x
FD60	x	x	✓	x	x
FD120	x	x	✓	x	x
FD240	x	x	x	x	x
E 20	x	x	✓	x	x
EI 20	x	x	✓	x	x
E 30	x	x	✓	x	x
EI 30	x	x	✓	x	x
E 60	x	x	✓	x	x
EI 60	x	x	✓	x	x
E 90	x	x	✓	x	x
EI 90	x	x	✓	x	x
E 120	x	x	✓	x	x
EI 120	x	x	✓	x	x
E 240	x	x	x	x	x
EI 240	x	x	x	x	x

Key:

- ✓ - approved
- x - Not approved

ALLEGION (UK) LIMITED

CF 109

BRITON 996 SERIES OVERHEAD DOOR CLOSERS

10. Doors are classified as the following types:

Code ITT - 20 minute to 120 minute doorsets containing intumescent seals and consisting of timber faced and edged leaves with timber, cellulosic or mineral cores, hung in timber-based frames.

Code ITM - 20 minute to 120 minute doorsets containing intumescent seals and consisting of timber faced and edged leaves with timber, cellulosic or mineral cores, hung in steel frames.

Code ITC - 20 minute to 120 minute doorsets containing intumescent seals and consisting of timber faced and edged leaves with timber, cellulosic or mineral cores, hung in proprietary composite frames, of which the principal material is other than timber or metal but which may include any other materials.

Code MM - 20 to 240 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames without intumescent seals.

Code IMM - 20 to 240 minute doorsets consisting of uninsulated or insulated predominantly steel leaves, hung in steel frames with intumescent seals.

Scope of Approval:

- Doors may not include uninsulated glass above 20% of their total area. Uninsulated glass shall not be included directly beneath the door closer body
- All closer models are only approved in the fitting applications detailed with their classification codes.
- The closer may not be fitted to timber doorsets without leaf/frame edge intumescent protection.
- Mechanical Hold open option is not approved.
- The following functions are supported by this certification:

Closer Ref.	Latch Control	Backcheck	Delayed-Action
9963	Yes	No	No
9964	Yes	No	No
9965	Yes	No	No



ALLEGION (UK) LIMITED

CF 109

BRITON 996 SERIES OVERHEAD DOOR CLOSERS

Classification codes

This approval provides the following classification for the closer listed above:

Briton 9963 Mounted in regular, transom and parallel arm positions:

3	8	3	1	1	3
---	---	---	---	---	---

Briton 9964 Mounted in regular, transom and parallel arm positions:

3	8	4	1	1	3
---	---	---	---	---	---

Briton 9965 Mounted in regular, transom and parallel arm positions:

3	8	5	1	1	3
---	---	---	---	---	---

Further Information

Further information regarding the details contained in this certificate may be obtained from Allegion (UK) Limited (Tel: +44 (0) 121 380 2400).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).