



CERTIFICATE OF APPROVAL

No CF 5506

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

ALLEGION (UK) LIMITED

35 Rocky Lane, Aston, Birmingham, B6 5RQ, UK
Tel: +44 (0) 121 380 2400

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

Briton 376 Range of Panic Exit
Devices and Emergency Exit
Devices and Associated
Accessories

TECHNICAL SCHEDULE

TS26 The Contribution of Panic
Exit Devices to the Fire
Resistance of Door Assemblies

TS31 The Contribution of
Emergency Exit Devices to the
Fire Resistance of Door
Assemblies

Signed and sealed for and on behalf of Warringtonfire Testing and Certification Limited

Paul Duggan
Certification Manager



Issued: 12th January 2017
Revised: 3rd June 2020
Valid to: 11th July 2023

Page 1 of 10



CERTIFICATE No. CF5506 ALLEGION (UK) LIMITED

Allegion (UK) Limited – Briton 376 range of Panic & Emergency Exit Devices

1. This approval relates to the Briton 376 range of panic and emergency exit devices and associated accessories (see specific retractions to the scope for Outside Access) as follows:

Ref.	Description
372	Push Pad Exit Bolt
376	Panic Exit Bolt
377	Panic Exit For Double Doors
378	Panic Exit Latch
379.N	Mortice Panic Nightlatch
389.N	Mortice Push Pad Nightlatch
1438	Push Pad Exit Latch
1413	Outside Access Device

2. This certification is provided to the client for their own purposes and we cannot opine on whether it will be accepted by Building Control authorities or any other third parties for any purpose.
3. This approval relates to the use of the family of exit devices with the following door assemblies:-

Previously proven unlatched, door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber or metal frames containing intumescent seals having a fire resistance up to 120 minutes (Codes ITT and ITM)*.

Previously proven unlatched, door assemblies consisting of non-metallic faced and edged leaves proprietary composite frames, of which the principal material is other than timber or metal, but may include other materials having a fire resistance up to 120 minutes (Codes ITC)*.

Previously proven unlatched, door assemblies consisting of metallic leaves with metallic frames having a fire resistance up to 240 minutes* (Codes MM and IMM)*

*See Tables in section 10, 11, 12 & 13 for full details of certificated scope for each product.





CERTIFICATE No. CF5506 ALLEGION (UK) LIMITED

Allegion (UK) Limited – Briton 376 range of Panic & Emergency Exit Devices

4. The exit devices are approved on the basis of:
 - i) Initial type testing to EN 1125 and EN 179 for mechanical properties
 - ii) Initial type testing to EN 1634-1 for the fire resistance performance of doorsets
 - iii) An appraisal against TS26 and TS 31
 - iv) Certification of quality management system
 - v) Inspection and surveillance of factory production control
 - vi) On-going audit testing in accordance with EN 1125: 2008 requirements and EN 179: 2008 requirements
5. It is a requirement of this report that the doorsets to which the panic hardware is fitted shall have been previously tested unlatched in the configuration required.
6. The purpose of the appraisal is only to consider the influence of fitting the proposed hardware items to a doorset, and not its ability to provide an essential latching action.
7. This approval is applicable only to the specified exit devices and relevant accessories when used with door assemblies of proven fire resistance (as defined by EN 1634-1) which have previously been successfully tested unlatched, but fitted with a CERTIFIRE approved door closer. Failure to install the device and accessories in the appropriate manner will invalidate this certificate of approval.
8. Where these devices are to be fitted to pairs of doors with rebated meeting stiles, this typically represents a more onerous condition compared with plain meeting stile details tested. It is therefore assumed the proposed doorsets have suitable test evidence for rebated meeting stiles.
9. The approval relates to on-going production. Product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

CERTIFICATE No. CF5506 ALLEGION (UK) LIMITED

Allegion (UK) Limited – Briton 376 range of Panic & Emergency Exit Devices

10. The following table shows acceptable doorsets types and fire resistance periods for the 372, 376, 377, 378 and 1438 series of surface mounted panic and emergency exit devices, **excluding** any Outside Exit Devices (OAD's):

Class	Approved Door Type				
	IMM	MM	ITT	ITM	ITC
FD20	✓*	✓*	✓	✓	✓
FD30	✓*	✓*	✓	✓	✓
FD60	✓*	✓*	✓	✓	✓
FD90	✓*	✓*	✓	✓	✓
FD120	✓*	✓*	✓	✓	✓
FD240	✓*	✓*	✗	✗	✗
E 20	✓*	✓*	✓	✓	✓
EI 20	✓*	✓*	✓	✓	✓
E 30	✓*	✓*	✓	✓	✓
EI 30	✓*	✓*	✓	✓	✓
E 60	✓*	✓*	✓	✓	✓
EI 60	✓*	✓*	✓	✓	✓
E 90	✓*	✓*	✓	✓	✓
EI 90	✓*	✓*	✓	✓	✓
E 120	✓*	✓*	✓	✓	✓
EI 120	✓*	✓*	✓	✓	✓
E 240	✓*	✓*	✗	✗	✗
EI 240	✓*	✓*	✗	✗	✗

Key:

✓ - approved

✗ - Not approved

✓* The 376A variant is not certificated for use on MM/IMM doorsets



CERTIFICATE No. CF5506 ALLEGION (UK) LIMITED

Allegion (UK) Limited – Briton 376 range of Panic & Emergency Exit Devices

11. The following table shows acceptable doorsets types and fire resistance periods for the 372, 376, 377, 378 and 1438 series of surface mounted panic and emergency exit devices, **including** Outside Exit Devices (OAD's):

Class	Approved Door Type				
	IMM	MM	ITT	ITM	ITC
FD20	✓	✓	✓	✓	✗
FD30	✓	✓	✓	✓	✗
FD60	✓	✓	✓	✓	✗
FD90	✓	✓	✗	✗	✗
FD120	✓	✓	✗	✗	✗
FD240	✗	✗	✗	✗	✗
E 20	✓	✓	✓	✓	✗
EI 20	✓	✓	✓	✓	✗
E 30	✓	✓	✓	✓	✗
EI 30	✓	✓	✓	✓	✗
E 60	✓	✓	✓	✓	✗
EI 60	✓	✓	✓	✓	✗
E 90	✓	✓	✗	✗	✗
EI 90	✓	✓	✗	✗	✗
E 120	✓	✓	✗	✗	✗
EI 120	✓	✓	✗	✗	✗
E 240	✗	✗	✗	✗	✗
EI 240	✗	✗	✗	✗	✗

Key:

- ✓ - approved
✗ - Not approved





CERTIFICATE No. CF5506

ALLEGION (UK) LIMITED

Allegion (UK) Limited – Briton 376 range of Panic & Emergency Exit Devices

12. The following table shows acceptable doorsets types and fire resistance periods for the 379 and 389 panic and emergency exit mortice operators, **excluding** Outside Exit Devices (OAD's):

Class	Approved Door Type				
	IMM	MM	ITT	ITM	ITC
FD20	✓	✓	✓	✗	✗
FD30	✓	✓	✓	✗	✗
FD60	✓	✓	✓	✗	✗
FD90	✓	✓	✗	✗	✗
FD120	✓	✓	✗	✗	✗
FD240	✓	✓	✗	✗	✗
E 20	✓	✓	✓	✗	✗
EI 20	✓	✓	✓	✗	✗
E 30	✓	✓	✓	✗	✗
EI 30	✓	✓	✓	✗	✗
E 60	✓	✓	✓	✗	✗
EI 60	✓	✓	✓	✗	✗
E 90	✓	✓	✗	✗	✗
EI 90	✓	✓	✗	✗	✗
E 120	✓	✓	✗	✗	✗
EI 120	✓	✓	✗	✗	✗
E 240	✓	✓	✗	✗	✗
EI 240	✓	✓	✗	✗	✗

Key:

- ✓ - approved
✗ - Not approved

CERTIFICATE No. CF5506 ALLEGION (UK) LIMITED

Allegion (UK) Limited – Briton 376 range of Panic & Emergency Exit Devices

13. The following table shows acceptable doorsets types and fire resistance periods for the 379 and 389 panic and emergency exit mortice operators, **including** Outside Exit Devices (OAD's):

Class	Approved Door Type				
	IMM	MM	ITT	ITM	ITC
FD20	✓	✓	✓	✗	✗
FD30	✓	✓	✓	✗	✗
FD60	✓	✓	✓	✗	✗
FD90	✓	✓	✗	✗	✗
FD120	✓	✓	✗	✗	✗
FD240	✗	✗	✗	✗	✗
E 20	✓	✓	✓	✗	✗
EI 20	✓	✓	✓	✗	✗
E 30	✓	✓	✓	✗	✗
EI 30	✓	✓	✓	✗	✗
E 60	✓	✓	✓	✗	✗
EI 60	✓	✓	✓	✗	✗
E 90	✓	✓	✗	✗	✗
EI 90	✓	✓	✗	✗	✗
E 120	✓	✓	✗	✗	✗
EI 120	✓	✓	✗	✗	✗
E 240	✗	✗	✗	✗	✗
EI 240	✗	✗	✗	✗	✗

Key:

- ✓ - approved
✗ - Not approved



CERTIFICATE No. CF5506 ALLEGION (UK) LIMITED

Allegion (UK) Limited – Briton 376 range of Panic & Emergency Exit Devices

14. Doors are classified as the following types:

Type MM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that do not contain intumescent materials in the frame to leaf gap.

Type IMM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that contain intumescent materials in the frame to leaf gap.

Type ITT - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in timber frames

Type ITM - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in metal frames.

Type ITC - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in proprietary composite frames, of which the principal material is other than timber or metal but which may include any other materials.

Scope of Approval:

- The panic hardware may not be fitted to timber doorsets without perimeter intumescent fire seals within the frame rebate or edge of the door leaf.
- This approval relates to the following items in the Allegion Hardware Panic and Emergency Exit Devices and associated accessories:

PUSH BAR VERTICAL PANIC BOLTS	376
	376.A*
	376.P
	376.D
	376.PD
	376M
	376M.P
	376OEM
	376OEM.P

* The 376A variant is not certificated for use on MM/IMM doorsets





CERTIFICATE No. CF5506 ALLEGION (UK) LIMITED

Allegion (UK) Limited – Briton 376 range of Panic & Emergency Exit Devices

Scope of Approval – Cont'd:

PUSH BAR RIM PANIC LATCHES	378.L
	378.R
	378.D.L
	378.D.R
	378M.L
	378M.R
	378OEM.L
	378OEM.R
PUSH BAR DOUBLE REBATED DOOR PANIC SETS	377.L
	377.R
PUSH PAD VERTICAL EMERGENCY BOLTS	372
	372M
	372OEM
	372.P
	372M.P
	372OEM.P
PUSH PAD VERTICAL EMERGENCY BOLTS	1438.L
	1438.R
	1438M.L
	1438M.R
	1438OEM.L
	1438OEM.R
OUTSIDE ACCESS DEVICE	1413.KE
	1413.NC.KE
	1413.LE
	1413.NC.LE
	1413OEM.KE
	1413OEM.NC.KE
	1413OEM.LE
	1413OEM.NC.LE

Page 9 of 10 Signed
V/010

Issued: 12th January 2017
Revised: 3rd June 2020
Valid to: 11th July 2023



CERTIFICATE No. CF5506 ALLEGION (UK) LIMITED

Allegion (UK) Limited – Briton 376 range of Panic & Emergency Exit Devices

Scope of Approval – Cont'd:

PUSH BAR MORTICE PANIC OPERATORS	379.N
	379.NA
	379.ND
	379M.N
	379OEM.N
PUSH PAD MORTICE EMERGENCY OPERATORS	389.N
	389M.N
	389OEM.N

Classification codes

The approval provides the following classifications:

376, 377, 378 and 379 series (push bar to EN1125)

3	7	6	B	1	3	2	2	A	A
---	---	---	---	---	---	---	---	---	---

372, 389 and 1438 series (push pad to EN179)

3	7	6	B	1	3	4	2	B	A
---	---	---	---	---	---	---	---	---	---

Further Information

Further information regarding the details contained in this data sheet may be obtained from Allegion (UK) Limited (Tel: +44 (0) 121 380 2400).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

Page 10 of 10 Signed
V/010

Issued: 12th January 2017
Revised: 3rd June 2020
Valid to: 11th July 2023