
CERTIFICATE OF APPROVAL

No CF 5512

This is to certify that, in accordance with
TS00 General Requirements for Certification of Fire Protection Products
The undermentioned products of

ALLEGION (UK) LIMITED

35 Rocky Lane, Aston, Birmingham, B6 5RQ, UK
+44 (0) 121 380 2400

Have been assessed against the requirements of the Technical Schedule(s)
denoted below and are approved for use subject to the conditions
appended hereto:

CERTIFIED PRODUCT

Surface Mounted Overhead
Closers referenced Briton
131.XX, Bricard 61311XX, Cisa
C1455.03.0.XX, ITO H131.XX and
Falcon LA-C234

TECHNICAL SCHEDULE

TS 34 - The Contribution Of
Controlled Door Closing
Devices And Accessories To
Fire Resisting Doorsets

Signed and sealed for and on behalf of Exova (UK) Limited trading as
Warrington Certification



Paul Duggan
Certification Manager



Issued: 5th January 2017
Revised: 18th December 2017
Valid to: 4th January 2022

Page 1 of 6



CERTIFICATE No CF 5512 ALLEGION (UK) LIMITED

Allegion (UK) Limited surface mounted overhead door closer

1. This approval applies to Allegion rack and pinion overhead door closer models. This approval relates to the following overhead mounted door closing devices and configurations:

	Link-arms			Slide arms			
	Projecting arm (Fig. 1) <i>Body door mounted on pull face</i>	Projecting arm (Fig. 61) <i>Body transom mounted on push face</i>	Parallel arm (Fig. 6) <i>Body door mounted on push face</i>	Body door mounted on pull face	Body transom mounted on push face	Body door mounted on push face	Body transom mounted on pull face
Briton 131.XX	✓	✗	✓	✗	✗	✗	✗
Bricard 61311XX	✓	✗	✓	✗	✗	✗	✗
Cisa C1455.03.0.XX	✓	✗	✓	✗	✗	✗	✗
ITO H131.XX	✓	✗	✓	✗	✗	✗	✗
Falcon LA-C234	✓	✗	✓	✗	✗	✗	✗

Key: ✓ - approved ✗ - Not approved

Note: Where alternative arms for non-fire applications are included within the packaging, the use of these components on fire resisting door assemblies will invalidate the certification.

2. This approval relates to its use with the following door assemblies: -

Latched and unlatched, intumescent sealed door assemblies consisting of timber faced and edged leaves with timber, cellulosic or mineral cores in timber frames having a fire resistance up to 120 minutes (CERTIFIRE Code ITT).

Latched and unlatched, door assemblies consisting of non-metallic faced and edged leaves proprietary composite frames, of which the principal material is other than timber or metal, but may include other materials having a fire resistance up to 120 minutes (Codes ITC).

Latched and unlatched, door assemblies consisting of metal faced and edged leaves in metal frames, fully-insulated for the required classification period, with or without intumescent sealing, and having a fire resistance up to 240 minutes (Code IMM/MM).

CERTIFICATE No CF 5512

ALLEGION (UK) LIMITED

Allegion (UK) Limited surface mounted overhead door closer

3. This certification is designed to demonstrate compliance of the product or system specifically with Approved Document B (England and Wales), the Technical Handbooks (Scotland) and Technical Booklet E (N. Ireland). If compliance is required to other regulatory or guidance documents there may be additional considerations or conflict to be taken into account.
4. The closer is approved on the basis of:
 - i) Initial type testing to EN1154 and BS EN 1634-1: 2000
 - ii) An appraisal against TS34
 - iii) Inspection of quality management system
 - iv) Inspection and surveillance of factory production control
 - v) Ongoing audit testing in accordance with EN 1154 requirements
5. The closers shall be fixed with screws supplied by the closer manufacturer. Bolt-through fixings shall not be used.
6. Where the closers are fitted to door leaves or frames that are manufactured from mineral composite-based materials, or low-density cellulosic-based material, the door assembly shall have previously been shown capable of accommodating the installation of closers at the head of the doorset, without detriment to the door assembly's performance.
7. This approval is applicable only to the specified closers when mounted in the applications stated above and under the classification codes section of this certificate and used with door assemblies of proven fire resistance (as defined in BS EN 1634-1 or BS 476: Part 22: 1987) and having power ratings appropriate to the leaf sizes subject to a minimum size 3 (as specified in BS EN 1154).
8. The approval relates to ongoing production. Product and/or its immediate packaging is identified with the manufacturer's name, the product name or number, the CERTIFIRE name or name and mark, together with the CERTIFIRE certificate number and application where appropriate.

CERTIFICATE No CF 5512 ALLEGION (UK) LIMITED

Allegion (UK) Limited surface mounted overhead door closer

9. The following table show acceptable doorset types and fire resistance periods:

Class	Approved Door Type				
	MM	IMM	ITT	ITM	ITC
FD20	✓*	✓*	✓	✗	✓
FD30	✓*	✓*	✓	✗	✓
FD60	✓*	✓*	✓	✗	✓
FD120	✓*	✓*	✓	✗	✓
FD240	✓*	✓*	✗	✗	✗
E 20	✓*	✓*	✓	✗	✓
EI 20	✓*	✓*	✓	✗	✓
E 30	✓*	✓*	✓	✗	✓
EI 30	✓*	✓*	✓	✗	✓
E 60	✓*	✓*	✓	✗	✓
EI 60	✓*	✓*	✓	✗	✓
E 90	✓*	✓*	✓	✗	✓
EI 90	✓*	✓*	✓	✗	✓
E 120	✓*	✓*	✓	✗	✓
EI 120	✓*	✓*	✓	✗	✓
E 240	✓*	✓*	✗	✗	✗
EI 240	✓*	✓*	✗	✗	✗

Key:

- ✓ - approved
- ✗ - Not approved
- ✓* - Fully-insulated steel-based doorsets only.

CERTIFICATE No CF 5512 ALLEGION (UK) LIMITED

Allegion (UK) Limited surface mounted overhead door closer

10. Doors are classified as the following types:

Type MM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that do not contain intumescent materials in the frame to leaf gap.

Type IMM - 20 minute to 240 minute doorsets that consist of metallic leaves in metallic frames that contain intumescent materials in the frame to leaf gap.

Type ITT - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in timber frames

Type ITM - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in metal frames.

Type ITC - 20 minute to 120 minute doorsets containing intumescent seals and consisting of non-metallic faced and edged leaves hung in proprietary composite frames, of which the principal material is other than timber or metal but which may include any other materials.

Scope of Approval:

- Doors may not include uninsulated glass above 20% of their total area.
- All closer models are only approved in the fitting applications detailed with their classification codes.
- The closer may not be fitted to timber doorsets without leaf/frame edge intumescent protection.
- Closers are only approved for use on steel-based doorsets that are fully-insulated for the required classification period.
- Mechanical Hold open option is not approved.

Classification codes:

Figure 1 Projecting arm applications:

3	8	4 3	1	1	3
---	---	--------	---	---	---

Figure 6 parallel arm applications:

3	8	3	1	1	3
---	---	---	---	---	---



CERTIFICATE No CF 5512 ALLEGION (UK) LIMITED

Allegion (UK) Limited surface mounted overhead door closer

Further Information

Further information regarding the details contained in this certificate may be obtained from Allegion (UK) Limited (Tel: +44 (0) 121 380 2400).

Further information regarding CERTIFIRE certification and other approved products can be obtained from CERTIFIRE (Tel: 01925 646777).

Page 6 of 6 Signed
K/002

A handwritten signature in black ink, appearing to read "Paul Hogg".

Issued: 5th January 2017
Revised: 18 the December 2017
Valid to: 4th January 2022