

Notified Body No. 2812

## Certificate of Constancy of Performance

### 2812-CPR-AE0020

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

## LCN 4040SE Electrically powered hold open door closer (Size 3 to 4)

**Intended use:- For use on fire rated single leaf and double leaf doors  
DOOR MOUNT PULL SIDE APPLICATION.**

Essential characteristics	Performance	Harmonised technical specification
<b>Mechanical Test Evidence: 91PCT &amp; 163053</b> <b>Fire Test Evidence: WF 142058 Iss 6 / WF 136807 Iss 2 &amp; WF 137144</b>		
<u>Ability to release</u> 5.1.2 release from any angle 5.1.3 Not possible to inhibit the release 5.1.4 Supply voltage 5.1.5 External electrical connection 5.1.6 Inlet for external wiring  5.2.1 General 5.2.2 Electrical release 5.2.3 Door closing device requirements  <u>Requirements</u> 5.2.4 Durability 5.2.5 Angle of hold open 5.2.6 Manual release 5.2.7 Continuous hold open 5.2.8 Overload performance 5.2.9 Delayed release 5.2.10 Electrical performance 5.1.11 Temperature Rise 5.1.12 Damage 5.1.13 Fire / smoke doors	Pass Pass 24V Pass Pass  Pass Pass  Pass Pass > 65° Pass Pass NPD Pass Pass Pass Grade 1	EN 1155:1997+A1:2002/AC:2006
Essential characteristics	Performance	Harmonised technical specification
Durability of Ability to release 5.2.4 Durability 5.2.14.1 corrosion 5.2.14.2 corrosion	500,000 Test Cycles Grade 3 (96 hours) Pass	EN 1155:1997+A1:2002/AC:2006
<u>Dangerous Substances</u> <u>Annex ZA3</u>	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the Electrically Powered Hold Open Door closer do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations	EN 1155:1997+A1:2002/AC:2006

Notified Body No. 2812

## Certificate of Constancy of Performance

### 2812-CPR-AE0020

Placed on the Market under the name of:

**Allegion (UK) Ltd  
35 Rocky Lane  
Aston  
Birmingham  
West Midlands  
B6 5RQ  
United Kingdom**

and produced in the manufacturing plant:

**E014110-7**

**This is coded format, and the information is held by the Notified Body.**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

**EN 1155:1997+A1:2002/AC:2006**

Under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **29/10/2020** and reissued on **13/02/2026** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the notified product certification body.

CE Marking certificate valid to: **20/02/2029**

ERO Project Reference: **ERO 034621 P2990**



**Pascal Coget  
European Certification –General Manager**

CSF408-NL 8.0