

Notified Body No. 2812

## Certificate of Constancy of Performance 2812-CPR-AG5077

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

### Schlage L9000 Series Mechanical Locks See Annex A

**Intended use: For use on fire/smoke compartmentation doors**

Essential characteristics	Performance	Harmonised technical specification
Mechanical test evidence: WIL 332690-1, WIL 332690-2, WIL 332690-4, WIL 332690-5, WIL 332690-6, WIL 332690-7, WIL 332690-8, WIL 332690-9, WIL 332690-10 & WIL 332690-11 Fire test evidence: WF 332444		
Self-closing 5.4.2 Closing force	Grade 5 = 200Kg door mass with 25N maximum closing force.	EN 12209:2003 / AC:2005
5.1.2 Re-latching force of latch bolt	>2.5N	
Durability of self-closing 5.3.1 Durability of latch action	Grade X = 200,000 cycles with 120N side load on latch bolt.	
Ability to maintain the door in the closed position and not contribute to its spread of fire	Grade 1: suitable for use on fire/smoke resistant door assemblies	
Dangerous substances	Pass: the materials in the lock do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	

## Certificate of Constancy of Performance

**2812-CPR-AG5077**

Placed on the market under the name of:

**Allegion (UK) Ltd  
35 Rocky Lane  
Aston  
Birmingham  
West Midlands  
B6 5RQ  
United Kingdom**

and produced in the manufacturing plant

**AF/002 & B/052**

**This is coded format and the information is held by the Notified Body**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard:

**EN 12209:2003 / AC:2005**

Under System 1 for the performance set out in this certificate are applied and that the factory production control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **30/10/2020** and reissued on **25/01/2023** and will remain valid as long as neither the harmonised standard, the construction product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: **24/01/2026**

ERO Project Reference: **ERO 034621 P1748**



Paul Duggan  
Certification Manager

CSF408-NL 7.0

## Certificate of Constancy of Performance

### 2812-CPR-AG5077

#### Annex A

Model No.	Description	Model No.	Description
L9010	Passage Lock	L9465	Closet/Storeroom Lock
L9040	Bath/Bedroom Lock	L9473	Dormitory/Bedroom Lock
LV9040	Bath/Bedroom Lock with Vandlgard	L9480	Storeroom Lock with Deadbolt
L9044	Privacy Lock	LV9480	Storeroom Lock with Deadbolt with Vandlgard
LV9044	Privacy Lock with Vandlgard	L9485	Hotel or Restroom Lock
L9444	Privacy with Deadbolt	LV9485	Hotel or Restroom Lock with Vandlgard
LV9444	Privacy with Deadbolt with Vandlgard	L9486	Hotel Lock
L9440	Privacy with Deadbolt	LV9486	Hotel Lock with Vandlgard
LV9440	Privacy with Deadbolt with Vandlgard	L9496	Privacy Lock
L9050	Office & Inner Entry Lock	LV9496	Privacy Lock with Vandlgard
LV9050	Office & Inner Entry Lock with Vandlgard	L9060	Apartment Entrance Lock
L9056	L9050 with Automatic Unlocking	LV9060	Apartment Entrance Lock with Vandlgard
LV9056	L9050 with Automatic Unlocking with Vandlgard	L9071	Classroom Security Lock
L9070	Classroom Lock	LV9071	Classroom Security Lock with Vandlgard
LV9070	Classroom Lock with Vandlgard	L9082	Institution Lock
L9080	Storeroom Lock	LV9082	Institution Lock with Vandlgard
LV9080	Storeroom Lock with Vandlgard	L9457	Classroom Security Lock
L9453	Entrance Lock	LV9457	Classroom Security Lock with Vandlgard
LV9453	Entrance Lock with Vandlgard	L9466	Storeroom/Utility Room Lock
L9456	Corridor Lock	L9482	Institution Lock with Deadbolt
LV9456	Corridor Lock with Vandlgard	LV9482	Institution Lock with Deadbolt with Vandlgard
L9458	Classroom Security Lock with Auxiliary Latch		
LV9458	Classroom Security Lock with Auxiliary Latch with Vandlgard		

#### Accessories

Model Number	Description
XL11-635	Adds fixed dummy trim to both sides
XL11-886	Adds fixed dummy trim outside, active lever inside
L583-375	"Do not disturb" indicator changed to "Occupied" indicator
XL11-557	Tamper resistant Torx® screws