

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AG5077

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product:

Schlage L9000 Series Mortice Locks See Annex A

Intended use: For use on fire/smoke compartmentation doors

Essential characteristics	Performance	Harmonised technical specification
Mechanical test evidence: WIL 332690-1, WIL 332690-2, WIL 332690-4, WIL 332690-5, WIL 332690-6, WIL 332690-7, WIL 332690-8, WIL 332690-9, WIL 332690-10 & WIL 332690-11 Fire test evidence: WF 332444 & WF 335640 iss.5		
Self-closing ability 5.4.2 Closing force 5.1.2 Return force of latch bolt	Grade 5: 200Kg door mass with 25N maximum closing force. >2.5N	EN 12209:2003 / AC:2005
Durability of self-closing action 5.3.1 Durability of latch action	Grade X: 200,000 cycles with 120N side load on latch bolt.	
Ability to maintain the door in the closed position and not contribute to its spread of fire 5.2.1 Resistance to side load on latch bolt 5.5 Suitability for use on fire/smoke doors	Grade 3: 3kN Grade 1: suitable for use on fire/smoke resistant door assemblies	
Control of dangerous substances 5.1.1 Dangerous substances	Pass: The materials in the lock do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations (1)	

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AG5077

Placed on the Market under the Name of:

**Allegion (UK) Ltd
35 Rocky Lane
Aston
Birmingham
West Midlands
B6 5RQ
United Kingdom**

and produced in the manufacturing plants:

E014110-10 & E014110-16

This is coded format, and the information is held by the Notified Body.

This certificate attests that all provisions concerning the Assessment and Verification of Constancy of Performance described in Annex ZA of the standard(s):

EN 12209:2003 / AC:2005

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **30/10/2020** and reissued on **23/01/2026** and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

Valid to: **24/01/2029**

ERO Project Reference: **ERO 034621 P3021**



**Pascal Coget
General Manager – European Certification**

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AG5077

Annex A

Model No.	Description	Backset	Centres
L9010	Passage latch Square forend	70mm	98mm
L9040	Bath/bedroom privacy lock Square forend	70mm	98mm
LV9040	Bath/bedroom privacy lock w/ Vandlgard Square forend	70mm	98mm
L9044	Privacy lock w/ coin-turn Square forend	70mm	98mm
LV9044	Privacy lock w/ coin-turn & Vandlgard Square forend	70mm	98mm
L9050	Entrance/office lock Square forend	70mm	98mm
LV9050	Entrance/office lock w/ Vandlgard Square forend	70mm	98mm
L9056	Entrance/office lock w/ automatic unlocking Square forend	70mm	98mm
LV9056	Entrance/office lock w/ automatic unlocking & Vandlgard. Square forend	70mm	98mm
L9060	Apartment entrance lock Square forend	70mm	98mm
LV9060	Apartment entrance lock w/ Vandlgard Square forend	70mm	98mm
L9070	Classroom lock Square forend	70mm	98mm
LV9070	Classroom lock w/ Vandlgard Square forend	70mm	98mm
L9071	Classroom security lock Square forend	70mm	98mm
LV9071	Classroom security lock w/ Vandlgard Square forend	70mm	98mm
L9080	Storeroom lock Square forend	70mm	98mm
LV9080	Storeroom lock w/ Vandlgard Square forend	70mm	98mm

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AG5077

Annex A

Model No.	Description	Backset	Centres
L9082	Institution lock Square forend	70mm	98mm
LV9082	Institution lock w/ Vandlgard Square forend	70mm	98mm
L9440	Privacy lock w/ deadbolt Square forend	70mm	98mm
LV9440	Privacy lock w/ deadbolt & Vandlgard Square forend	70mm	98mm
L9444	Privacy lock w/ deadbolt & coin-turn Square forend	70mm	98mm
LV9444	Privacy lock w/ deadbolt & coin-turn & Vandlgard. Square forend	70mm	98mm
L9453	Entrance/office lock w/deadbolt Square forend	70mm	98mm
LV9453	Entrance/office lock w/deadbolt & Vandlgard Square forend	70mm	98mm
L9456	Corridor lock w/ deadbolt Square forend	70mm	98mm
LV9456	Corridor lock w/ deadbolt & Vandlgard Square forend	70mm	98mm
L9457	Classroom security lock w/ deadbolt Square forend	70mm	98mm
LV9457	Classroom security lock w/ deadbolt & Vandlgard. Square forend	70mm	98mm
L9458	Classroom security lock w/ deadbolt & auxiliary latch. Square forend	70mm	98mm
LV9458	Classroom security lock w/ deadbolt & auxiliary latch & Vandlgard. Square forend	70mm	98mm
L9465	Closet/storeroom lock Square forend	70mm	98mm
L9466	Utility room/storeroom lock Square forend	70mm	98mm

Notified Body No. 2812

Certificate of Constancy of Performance

2812-CPR-AG5077

Annex A

Model No.	Description	Backset	Centres
L9473	Dormitory/bedroom lock Square forend	70mm	98mm
L9480	Storeroom lock w/ deadbolt Square forend	70mm	98mm
LV9480	Storeroom lock w/ deadbolt & Vandlgard Square forend	70mm	98mm
L9482	Institution lock w/ deadbolt Square forend	70mm	98mm
LV9482	Institution lock w/ deadbolt & Vandlgard Square forend	70mm	98mm
L9485	Faculty/hotel restroom lock w/ deadbolt Square forend	70mm	98mm
LV9485	Faculty/hotel restroom lock w/ deadbolt & Vandlgard. Square forend	70mm	98mm
LV9485 w/ XL11-557	Prison function lock Square forend	70mm	98mm
L9486	Faculty/hotel restroom lock w/ chevron indicator. Square forend	70mm	98mm
LV9486	Faculty/hotel restroom lock w/ chevron indicator & Vandlgard. Square forend	70mm	98mm
L9496	Corridor lock w/ chevron indicator Square forend	70mm	98mm
LV9496	Corridor lock w/ chevron indicator & Vandlgard. Square forend	70mm	98mm