

Notified Body No. 2812

Certificate of Constancy of Performance 2812-CPR- AAA5007

In compliance with Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product:

"VON DUPRIN 99/9875 (SEE ANNEX A) & 99/9847 (SEE ANNEX B) Series" Panic Exit devices

Intended use: For use on single and double leaf escape panic doors, & Locked doors on escape routes.

Essential characteristics	Performance	Harmonised technical specification
	Mechanical Test Evidence: WIL 330786 / WIL	
	331354 / WIL 331354-1 / WIL 423333 & WIL	
	436635	
	Fire Test Evidence: N/A	
Clause 4.2.1 Ability to release		
(for doors on panic routes)		
Release function	< 1 sec	
Panic exit device mounting	Pass	
Exposed edges and corners	> 0,5 mm	
Double doorset	Pass	
Single doorset	Pass	
Bar installation	Z < 150 mm	
Barlength	> 60%	
Bar projection	W< 100mm	
Bar end	Pass	
Operating bar face	> 18 mm	
Test rod	Pass	
Door face gap	> 25 mm	
Accessible gap	Pass	
Door free movement	Pass	
Top vertical bolt	Pass (ANNEX B ONLY)	
Keepers	Pass	
Keepers dimensions	Pass (ANNEX B ONLY)	
Door mass and dimensions	Door mass ≤ 200 Kg, door height ≤ 2500 mm, door	
	width ≤ 1015 mm	
Outside access device	Pass	EN 1125:2008
Release forces	< 80 N with the door unloaded, and < 220 N with the	
	door loaded with 1 000 N	
Security requirement	Grade 2	
Clause 4.2.1 Durability of ability to release against		
aging and degradation		
(for doors on panic routes)		
Corrosion resistance	Grade 3 : 96 h	
Temperature range	Operating forces at -10 C° and + 60 C° < 50% in	
	excess of the operating forces at	
	+20 C°	
Covers for vertical rods	Pass	
Lubrication	Lubrication every 20 000 cycles	
Re-engagement force	< 50 N	
Durability	Grade 7: 200 000 cycles	
Abuse resistance - Horizontal bar	1 000 N	
Abuse resistance -Vertical rod	500 N	
Final examination	< 80 N with the door unloaded, and < 220 N with the	
	door loaded with 1 000 N	



Certificate of Constancy of Performance 2812-CPR-AAA5007

Clause 4.2.1 Self closing ability C (for fire/smoke doors on panic routes) Re-engagement force	< 50 N	
Clause 4.2.1 Durability of self-closing ability C against aging and degradation (for fire/smoke doors on panic routes) Durability Re-engagement force	Grade 7: 200 000 cycles < 50 N	
Clause 4.2.1 Resistance to fire E (integrity) and I (insulation) (for fire doors on panic routes) Suitability of panic exit devices for use on fire resisting doorsets assemblies –	Grade 0: Not Suitable for use on fire/smoke single door assemblies.	EN 1125 : 2008
Additional requirements		
Clause 4.1.25 Control of Dangerous substances	If a reference to dangerous substances is added in the table ZA.1, the following claim is suggested: Pass: the materials in the hinge do not contain or release any dangerous substances in excess of the maximum levels specified in existing European material standards or any national regulations.	





Certificate of Constancy of Performance 2812-CPR-AAA5007

Von Duprin	- ·		Approved with Alternate Keepers and sockets				
Product Code	Single Door	Double Door	575	338	385A		
ANNEX A							
9875EO / 9875EO-F	X	X	X				
9975EO / 9975EO-F	X	X	X				
ANNEX B							
9847EO / 9847EO-F	X	X		Х	X		
9847EO / 9847EO-F w. EXT ROD	X	X		X	X		
9847EO / 9847EO-F LBR	X	X		X			
9847EO / 9847EO-F LBR w. EXT ROD	X	X		X			
9947EO / 9947EO-F	X	Х		X	X		
9947EO / 9947EO-F w. EXT ROD	Х	Х		X	X		
9947EO / 9947EO-F LBR	Х	Х		X			
9947EO / 9947EO-F LBR w. EXT ROD	X	X		X			

Above Abbreviations are – LBR = Less Bottom Rod / w. EXT ROD = Top Extension Rods

All of the above devices can be supplied with the additional options shown below

HD – **Hex Key Dogging**

LD - Less Dogging

PN – Pneumatic Latch Retraction

EL – Electric Latch Retraction

QEL- Quiet Electric Latch Retraction

99/9875 Series	V	✓	996L-M, 996L-NL-M, 996L-BE-M & 996L-DT-M
99/9847 Series	V	~	996L-R/V, 996L-NL-R/V, 996L-BE-R/V & 996L-DT





Certificate of Constancy of Performance 2812-CPR-AAA5007

Placed on the Market under the Name of

ALLEGION (UK) LTD
35 Rocky Lane
Aston
Birmingham
B6 5RQ
United Kingdom

and produced in the manufacturing plant

B/068

This is coded format and the information is held by the Notified Body

This certificate attests that all provisions concerning the Assessment and Verification of Constancy of Performance described in Annex ZA of the standard(s):

EN 1125:2008

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **16/02/2021** and reissued **09/06/2023** and will remain valid as long as neither the harmonised standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Notified Product Certification Body.

CE Marking certificate valid to: 15/02/2024

ERO Project Reference: EROWF10006

Paul Duggan Certification Manager

CSF408-NL 7.0

