

Approved body No. 1121

## Certificate of Constancy of Performance

**1121-CPR-UK-NA7623**

In compliance with Construction Products Regulation 2011 (retained EU law EUR 2011/305) as amended by the Construction Products (Amendment etc.) (EU Exit) Regulations 2019 and the Construction Products (Amendment etc.) (EU Exit) Regulations 2020, this certificate applies to the Construction Product:

### 6210 & 6223 Electric Strikes

**Intended use:** For use on fire/smoke compartmentation doors

Essential characteristics	Performance	Harmonised technical specification
	Mechanical test evidence:331144 Fire Test Evidence 334654	
Self closing ability		EN 14846: 2008
5.4 Door mass and closing force	Grade 8= 200Kg door mass with maximum 15N closing force	
Annex A Fire/Smoke test requirements	NPD	
Durability of self closing		
5.3.2 Durability of latch action	Grade C= 200,000 test cycles with no load on latchbolt	
Resistance to Fire E(integrity) I(insulation)(for fire doors)		
5.5 Suitability for use on fire/smoke doors	Grade F= classification time greater than 120min	

## **Certificate of constancy of performance**

**1121-CPR-UK-NA7623**

Placed on the market under the name of

**Allegion (UK) Ltd  
35 Rocky Lane  
Birmingham  
West Midlands  
B6 5RQ  
United Kingdom**

and produced in the manufacturing plant

**B/068**

**This is coded format and the information is held by the Approved Body**

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

**EN 14846:2008**

Under System 1 for the performance set out in this certificate are applied and that the Factory Production Control conducted by the manufacturer is assessed to ensure the constancy of performance of the construction product.

This certificate was first issued on **15/07/2021** and reissued on **19/12/2022** and will remain valid as long as neither the designated standard, the Construction Product, the AVCP methods nor the manufacturing conditions in the plant are modified significantly, or unless suspended or withdrawn by the Approved Product Certification Body.

UKCA certificate valid to: **31/03/2023**



0087

Paul Duggan  
Certification Manager

**Warringtonfire Testing and Certification Limited  
Suite 302, The Genesis Centre, Birchwood, Warrington, WA3 7BH, UK**