



Notified body No. 1121 Warrington Certification Limited, Holmesfield Road, Warrington, Cheshire, WA1 2DS, UK

Certificate of constancy of performance

1121-CPR-AD5118

In compliance with *Regulation 305/2011/EU* of the European Parliament and of the Council of 9 March 2011 (the Construction Products Regulation or CPR), this certificate applies to the construction product

Briton 2320B.T & 2321B.T Overhead door closers

Intended use: For use on fire rated single leaf and double leaf doors TRANSOM MOUNT & DOOR MOUNT PULL SIDE APPLICATIONS.

Essential characteristics	Performance	Harmonised technical specification
	Test Ref's : WIL 327071, 327071-2 Iss 2, 325004,	
	325004-2 & WF 153131 lss 7.	
Self closing		
5.2.1 General		_
5.2.2 Durability	500,000 test cycles	
5.2.3 Closing moment	Pass size 2 to 4	
5.2.4 Opening moment	Pass size 2 to 4	
5.2.5 Efficiency	>50% size 2	
5.2.5 Efficiency	>60% size 4	
5.2.6 Closing time	Pass	
5.2.7 Angles of operation	Grade 4, 180°	
5.2.8 Overload performance	Pass	
5.2.9 Temperature dependence	-15°C to +40°C	EN 1154:1996/A1:2002/AC:2006
5.2.10 Fluid leakage	Pass	
5.2.11 Damage	Pass	
5.2.12 Latch control	Pass	
5.2.13 Back check (optional)	Pass	
5.2.14 Delayed closing	NPD	
(optional)		
5.2.15 Adjustable closing force	Pass	
(optional)		
5.2.16 Zero position (double	NPD	
action door closers only)		
5.2.18 Fire/smoke door	Pass	
suitability		
Essential characteristics	Performance	Harmonised technical specification
Durability of Self Closing		
5.2.2 Durability	500,000 test cycles	
5.2.17.1 corrosion	Grade 3 (96 hours)]
5.2.17.2 corrosion	Pass	EN 1154:1996/A1:2002/AC:2006
Dangerous Substances	Pass: the materials in the door closer	LN 1104.1990/A1.2002/AC.2000
Annex ZA3	do not contain or release any	
	dangerous substances in excess of	
	the maximum levels specified in	
	existing European material standards	
	or any national regulations	

Page 1 of 4





Certificate of constancy of performance

1121-CPR-AD5118

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Briton 2320B.T Overhead door closer

Intended use: For use on fire rated single leaf and double leaf doors TRANSOM MOUNT PUSH SIDE APPLICATION.

Essential characteristics	Performance	Harmonised technical specification
Self closing		
5.2.1 General		
5.2.2 Durability	500,000 test cycles	
5.2.3 Closing moment	Pass size 2 to 4	
5.2.4 Opening moment	Pass size 2 to 4	
5.2.5 Efficiency	>50% size 2	
5.2.5 Efficiency	>60% size 4	
5.2.6 Closing time	Pass	
5.2.7 Angles of operation	Grade 3, > 105°	
5.2.8 Overload performance	Pass	
5.2.9 Temperature	-15°C to +40°C	EN 1154:1996/A1:2002/AC:2006
dependence		
5.2.10 Fluid leakage	Pass	
5.2.11 Damage	Pass	
5.2.12 Latch control	Pass	
5.2.13 Back check (optional)	NPD	
5.2.14 Delayed closing	NPD	
(optional)		
5.2.15 Adjustable closing force	Pass	
(optional)		
5.2.16 Zero position (double	NPD	
action door closers only)		
5.2.18 Fire/smoke door	Pass	
suitability		
Essential characteristics	Performance	Harmonised technical
		specification
Durability of Self Closing		
5.2.2 Durability	500,000 test cycles	
5.2.17.1 corrosion	Grade 3 (96 hours)]
5.2.17.2 corrosion	Pass	EN 1154:1996/A1:2002/AC:2006
Dangerous Substances	Pass: the materials in the door closer	EN 1154.1990/A1.2002/AC.2000
Annex ZA3	do not contain or release any	
	dangerous substances in excess of	
	the maximum levels specified in	
	existing European material standards	
	or any national regulations	





Certificate of constancy of performance

1121-CPR-AD5118

In compliance with *Regulation 305/2011/EU of the European Parliament and of the Council of 9 March 2011* (the Construction Products Regulation or CPR), this certificate applies to the construction product

Briton 2321B.T Overhead door closers

Intended use: For use on fire rated single leaf and double leaf doors DOOR MOUNT PUSH SIDE APPLICATION.

Essential characteristics	Performance	Harmonised technical specification
Self closing		
5.2.1 General		
5.2.2 Durability	500,000 test cycles	
5.2.3 Closing moment	Pass size 2 to 4	
5.2.4 Opening moment	Pass size 2 to 4	
5.2.5 Efficiency	>50% size 2	
5.2.5 Efficiency	>60% size 4	
5.2.6 Closing time	Pass	
5.2.7 Angles of operation	Grade 3, > 105°	
5.2.8 Overload performance	Pass	EN 1154:1996/A1:2002/AC:2006
5.2.9 Temperature dependence	-15°C to +40°C	EN 1154.1990/A1.2002/AC.2006
5.2.10 Fluid leakage	Pass	-
5.2.11 Damage	Pass	1
5.2.12 Latch control	Pass	1
5.2.13 Back check (optional)	Pass	1
5.2.14 Delayed closing	NPD	
(optional)		
5.2.15 Adjustable closing force	Pass	
(optional)		
5.2.16 Zero position (double	NPD	
action door closers only)		
5.2.18 Fire/smoke door	Pass	
suitability		
Essential characteristics	Performance	Harmonised technical
		specification
Durability of Self Closing		
5.2.2 Durability	500,000 test cycles	
5.2.17.1 corrosion	Grade 3 (96 hours)	1
5.2.17.2 corrosion	Pass	EN 1154:1996/A1:2002/AC:2006
Dangerous Substances	Pass: the materials in the door closer	EN 1154.1990/A1.2002/AC.2006
Annex ZA3	do not contain or release any	
	dangerous substances in excess of	
	the maximum levels specified in	
	existing European material standards	
	or any national regulations	





Certificate of constancy of performance

1121-CPR-AD5118

Produced for

Allegion (UK) Ltd Bescot Crescent, Walsall. West Midlands. WS1 4DL

and produced in the manufacturing plant

K/002

This is coded form and the information is held by the Notified Body.

This certificate attests that all provisions concerning the assessment and verification of constancy of performance and the performances described in Annex ZA of the standard(s)

EN 1154:1996/A1:2002/AC:2006

under system 1 of AVCP are applied and that

the product fulfils all the prescribed requirements set out above.

This certificate was first issued on **27/02/14** and will remain valid as long as the test methods and/or factory production control requirements included in the harmonised standard, used to assess the performance of the declared characteristics, do not change, and the product, and the manufacturing conditions in the plant are not modified significantly.

Paul Duggan Certification Manager Warrington Certification Ltd



Page 4 of 4